



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Lalkhuti Para, Suri, Birbhum, Pin:- 731101

Memo No.:FSR/211862506300017096

Date : 25-12-2025

From :
Divisional Fire Officer
Birbhum Division,
West Bengal Fire & Emergency Services

To :
Santiniketan Sishutirtha School
Village Ruppur, P.S-Santiniketan ,P.O Ruppur, Dist. Birbhum,West Bengal -731236

Sub : Fire Safety Certificate In favour of Existing educational building of LG+G+1 storied building under group of Educational occupancy, in favour of SANTINIKETAN SISHUTIRTHA SCHOOL, At Near Mouza-Dakshin Harirampur,J.L No-51,Khatian No-691&692,Plot No-782,Village-Ruppur,P.S-Santiniketan,P.O-Ruppur,Dist-Birbhum,West Bengal-731236

This is in reference to your AIN 211892506300009051 dated 25-Nov-2025 regarding Fire Safety Certificate In favour of Existing educational building of LG+G+1 storied building under group of Educational occupancy, in favour of SANTINIKETAN SISHUTIRTHA SCHOOL, At Near Mouza-Dakshin Harirampur,J.L No-51,Khatian No-691&692,Plot No-782,Village-Ruppur,P.S-Santiniketan,P.O-Ruppur,Dist-Birbhum,West Bengal-731236.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

Recommendation:-

- 1.Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed in the Driveway.
- 2.The interior finish Decorator of building shall be made with low flame spread material confirming to the I.S specification.
- 3.To eliminate Fire risk hazards, Good housekeeping both for inside and outside shall be strictly mentioned.



Sudipita Targore
Principal
Santiniketan Sishutirtha School

Rupaa Targore
Secretary
Santiniketan Sishutirtha

4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere tear in them, particularly lines above false ceiling and ducts.
5. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
6. Good housekeeping of all the building shall be provided.
7. The employee and security staff shall be conversant with installed Fire Fighting equipments of all the building and to operate in the event of Fire mock drill and testing.
8. Mock drill practise and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. DG set shall be protected with automatic Co2 or D.C.P Fire Extinguisher confirming I.S Specification.
10. First aid Fire Fighting system shall be provided as per I.S Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installation in the building to keep them perfectly good working condition at all the times.
12. If required the old lines shall have to be replaced with new lines the cables shall always be laid in M.S conduct pipe bonded to them earth.
13. Fire License to be obtained from the License Department of W.B.F&E.S for storing combustible materials.
14. If anything happens for improper life safety measures in the building within this period then authority will be responsible for that.
15. Fire safety certificate is valid for three years from the date of issues and has to be renewed after three years certifying about the satisfactory services, performance of all the Life Safety arrangement installation of the building.

Valid Upto : 23-Dec-2028

Memo No.:FSR/211862506300017096



Sundipta Tagore
Principal
Santiniketan Sishutirtha School

Rupam Tagore
Secretary
Santiniketan Sishutirtha

Signature Not Verified

Digitally Signed
Name: AMALESH BARUA
Date: 25-Dec-2025 23:05:59
Reason: D-Sign
Location: FSR/211862506300017096

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300009051

Existing AIN No. *
211892506300009051



Captcha *
rx4w

Search

Search



Service Name	AIN / Application Number	Approval Certificate Number / Registration Number	Date of Approval	Status	View More Details
Issuance of Fire Safety Certificate	211892506300009051	211892506300017096	25/12/2025	Approved	

Name of Enterprise to whom issued	Address of enterprise to whom issued	Date Of Application	Valid Till(date)
Santiniketan Sishutirtha School	Address Line 1-Village Ruppur, PS- Santiniketan, PO Ruppur, Dist. Birbhum, Village/Ward- Ruppur, PO- Ruppur BQ, PS- Santiniketan, Block- Bolpur Santiniketan, Sub Division- Bolpur, Pincode- 731236, Birbhum, West Bengal, India.	25/11/2025	24/12/2028

Principal
Santiniketan Sishutirtha School

Dipsa Tagore.
Secretary
Santiniketan Sishutirtha