Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CB4203 Dated: 09/02/26.

It is certified that an inspection team headed by Mr. Bireshwar Das, Asst. Engg.

(Name of Officers with designation) from Bolpur Mech. Division PHED

inspected the SANTINIKETAN SISHUTIRTHA SCHOOL, RUPPUR, SRINIKETAN, BIRBHUM, 731236

(Name & Address of the school) on 05/02/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. CB4203 dated 09/02/26

of Bolpur PHED Laboratory (PHED Lab) certified that the SANTINIKETAN SISHUTIRTHA SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till Jan., 2027

Bireshwar Das

Signature with Seal: .....
Name : BIRESHWAR DAS.
Designation : Assistant Engineer
Name & Address of the Office / Department : P.H.E. Dte. Govt. of W.B.

To,
The Principal,
Santiniketan Sishutirtha School,
(Name & Address of the Institution)
Ruppur, Sriniketan, Birbhum – 731236.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Sudipta Tagore

Principal
Santiniketan Sishutirtha School

Lipika Tagore.

Secretary
Santiniketan Sishutirtha

BOLPUR MECHANICAL DIVISION SUB DISTRICT LABORATORY

Chandanpur,P.O.-Raipur,P.S.-Bolpur,Birbhum,Pin-731204

Public Health Engineering Dte. Government of West Bengal

External Water (Physical ,Chemical & Bacteriology Combined) Test

Sample No.:CB 4203 **Report Issue Date : 09.02.2026**

Source Type: Drinking Water

Name Sample Location:Santiniketan Sishutirtha,Ruppur,Sriniketan,Birbhum.

Sender Name: Santiniketan Sishutirtha **Ref: online, dt 03/02/2026**

Sample received date: - 05.02.2026 **Sample Collected By: Sampling Asst.**

Date of Starting analysis: - 05.02.2026 **Date of completion:** 09.02.2026

Sl	Parameters	Unit	Recommended Drinking Water as per Standared Quality		Test Result
			Desirable Limit	Permissible Limit	
1	Colour	HU	5	15	2
2	pH	...	6.5	8.5	6.98
3	Turbidity	NTU	1	5	0.59
4	TDS	mg/l	500	2000	168
5	Arsenic	mg/l	0.01	no relaxation	0.00
6	Total Alkalinity	mg/l	200	600	64
7	Total Hardness	mg/l	200	600	70
8	Chloride	mg/l	250	1000	8
9	Fluoride	mg/l	1	1.5	0.439
10	Iron	mg/l	1	no relaxation	0.432
11	Manganese	mg/l	0.1	0.3	0.019
12	Total Coliform	CFU/100ml	0	0	0
13	Feacal Coliform	CFU/100ml	0	0	0

Sudripta Tagore

Principal
Santiniketan Sishutirtha School

Rupsa Tagore

Secretary
Santiniketan Sishutirtha

Chemist

Assistant Engineer
P.H.E DTE. W.B. Govt.
Bolpur Mechanical Div